



This copy has been made by or with the authority of Scottish and Southern Energy plc. It is a copy of the copyright document as issued by the copyright owner. It is not to be used for any other purpose without the prior written permission of the copyright owner. BASED UPON THE INFORMATION AVAILABLE TO THE CONTROLLER OF HER MAJESTY'S STATIONERY OFFICE. CONTROLLED BY THE NATIONAL ARCHIVE. SSSI DATA (c) Scottish Natural Heritage. Scottish and Southern Energy plc. Registered in Scotland No. 117116. Registered Office: Inverarmad Road, 200 Dundee Road, Perth PH1 5NQ.

Newtyle Pavilion

TAYSIDE & CENTRAL

Tel: 01738 453072

All Voltages

Scale : 1:1250

05/09/2014

N029834144

UNCONTROLLED COPY
Subject to revision without notice.

NORMAL DEPTH TO THE TOP OF THE
CABLE WHEN LAID.

FOOTPATH
by
over
0.40m 0.45m 0.60m 0.75m

ROAD CROSSING 0.65m 0.60m 0.75m 0.90m

l.v./services - upto 1000V
- over 1000V to 11,000V
h.v.
- 22,000V and 132,000V
e.h.v.

WARNING

These are the only cables shown in this diagram to the surface level. Trial holes must be taken to determine the actual depth of the cables. Avoiding danger from buried cables must be considered before commencing excavation work. (available from: HSE)

WHEN WORKING IN THE VICINITY OF OVERHEAD LINES THE HEALTH AND SAFETY GUIDANCE NOTE HSE SHOULD BE CONSULTED. (available from: HSE)

For plots at 1:10000 scale there may be more information visible at 1:500 scale. Responsibility is with the user of this map to check no further information exists at 1:500 scale.

